

## SECTION 009113 – ADDENDA

## PART 1 - Addenda

## 1.1 PROJECT INFORMATION

- A. Project Name: Tiemeyer Park Shelters 1, 2, & 3 Playground Improvements Project
- B. Owner: City Of St. Ann, 10405 St. Charles Rock Rd., St. Ann, Mo 63074
- C. Landscape Architect: John W. Wohlschlaeger, SWT Design, 7722 Big Bend Blvd., St. Louis, MO 63119
- D. Date of Addendum: October 4, 2019

## 1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is **unchanged by this Addendum**, at same time and location.
  - 1. Bid Date: Thursday October 10, 2019 at 2:00 p.m. CST

## 1.3 ATTACHMENTS

- A. This Addendum includes the following attached Documents:
  - 1. Document: Current Planholder List

## 1.4 This Addendum includes the following REVISIONS TO DRAWING SHEETS

- 1. SHEET L-001 NOTES AND LEGENDS
  - a. ADDED St. Louis Metropolitan Sewer District's (MSD) general notes under the Notes heading.
    - 1) CLARIFICATION to the added note #53:
      - a) No BMP's as defined by MSD are currently included in the scope of work.
    - 2) CLARIFICATION to the added note #54:

- a) No storm and sanitary sewer structures and appurtenances are currently proposed to be dedicated to MSD.

1.5 This Addendum includes the following RESPONSES TO BIDDER QUESTIONS:

- A. Question: Is it accurate that for tree removal that the stumps are to be removed as well or is grinding down the stumps acceptable?
1. Answer: Grinding down the stumps is acceptable. Stumps of trees that are to be removed are to be ground down a minimum 12" below finish grade. Any stumps that are in fill areas shall be ground down a minimum 12".
- B. Question: It is showing 6' safety fence for the tree protection, is it really supposed to be 4' tall safety fence?
1. Answer: 4' tall tree protection fencing is acceptable.
- C. Question: Who is the gravel supplier for the dry stream shown in the picture for Detail F/L-501?
1. Answer: The gravel in the dry stream picture in detail F/L-501 was supplied by Eureka Materials as part of the 2018 Tiemeyer Park Lake Improvement project, which is adjacent to this Playground Improvement project, approximately 600' to the west. The dry stream gravel mix for this Playground Improvement project is to match the gravel used in the adjacent Lake Improvement project.

END OF SECTION 009113



## Tiemeyer Park 123 Playground

### Planholder List

Company	Location	Contact Name	Email	Phone Number
SBC Contracting Inc	St. Louis, MO	Mike Woodling	<a href="mailto:miketwoodling@gmail.com">miketwoodling@gmail.com</a>	314-779-8449
Ideal Landscape Group	St. Louis, MO	Dave Buckel	<a href="mailto:buckel.dave@ideallandscape.com">buckel.dave@ideallandscape.com</a>	314-892-9500
Spencer Contracting Co.	Arnold, MO	Pat Buttner	<a href="mailto:pat.buttner@spencercontracting.com">pat.buttner@spencercontracting.com</a>	314-843-5166
Brookside Contracting	DeSoto, MO	Pat Downs	<a href="mailto:pcdowns@sbcglobal.net">pcdowns@sbcglobal.net</a>	636-337-8080
Byrne & Jones Construction	St. Louis, MO	Caitlin Kalicak	<a href="mailto:CKalicak@byrneandjones.com">CKalicak@byrneandjones.com</a>	314-567-7997
Kozeny Wagner Inc.	Arnold, MO	Stephen Strelau	<a href="mailto:sstrelau@kozenywagner.com">sstrelau@kozenywagner.com</a>	636-296-2012
RV Wagner Inc.	St. Louis, MO	Scott Inserra	<a href="mailto:scott@rvwagner.com">scott@rvwagner.com</a>	314-892-1600
Grumke Construction	St. Louis, MO	Mark Grumke	<a href="mailto:grumkegc@gmail.com">grumkegc@gmail.com</a>	314-779-8448
LanDesign	Wentzville, MO	Nick Krekeler	<a href="mailto:nick@lan-design.net">nick@lan-design.net</a>	636.332.4500
TJ's Lawn and Landscaping, Inc.	St. Charles, MO	Travis Brown	<a href="mailto:tjcutsgrass@hotmail.com">tjcutsgrass@hotmail.com</a>	636-723-8737
J. Oliver Construction LLC	Kansas City, MO	Lyndsay Moore	<a href="mailto:lyndsay@joliverconstruction.com">lyndsay@joliverconstruction.com</a>	913.276-9225
S. Bollinger and Associates	Hillsboro, MO	Steve Bollinger	<a href="mailto:steve.bollinger@att.net">steve.bollinger@att.net</a>	636.797.5820
ABCreative	St. Louis, MO	Ben Brown	<a href="mailto:ben@ABCreative.net">ben@ABCreative.net</a>	314.660.9160
Demien Construction	Wentzville, MO	Kaitlyn Demien		636.332.5465



